

PROFORMA FOR SAFE DRINKING WATER CERTIFICATE

No. 164

Dated: 8-9-2023

It is certified that an inspection team headed by Surendra Kumar Sharma junior chemist(Name of Officers with designation) from PHEO Laboratory Jaipur

(Name of Department/ Office) inspected the BIRLA SHISHU VIHAR, BITS

PILANI. (Name & Address of the school) on 8-9-23 (date of inspection) and found that theBirla Shishu Vihar (Name of school) has

safe drinking water facilities for the students and members of staff of the

institution and is maintaining

the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the Centra

l/State/U.T. Govt.

The above is valid for a period of one yearSignature with Seal: (सुरेन्द्र कुमार शर्मा)

Name

कनिष्ठ रसायनज्ञ
जन स्वा० अभि० विभाग

Designation

प्रयोगशाला, झुंझुनू

Name & Address of the Office/Department:

To

Birla Shishu Vihar
Pilani

(Name & Address of the institution)

Manager

Birla Shishu Vihar
Pilani - 333031 (Rajasthan)
CBSE Affn. No. : 1730263

PRINCIPAL

BIRLA SHISHU VIHAR
PILANI (RAJ)



**PUBLIC HEALTH ENGINEERING DEPARTMENT
LABORATORY JHUNJHUNU**

CHEMICAL EXAMINATION REPORT OF WATER

No. Lab. / Chem. /2023-24/ 464

Date - 8-9-2023

To,

THE PRINCIPAL

Birla Shishu Vihar

Pilani

Distt:- Jhunjhunu

Tehsil:-Pilani

Ref- Yours letter no. BSV/PO/16/2023-24/059 dated 4-9-2023

Date of Exam -8-9-2023

A	Name & Location of Source	IS-10500:2012		Water Sample Birla Shishu Vihar
B	Village/ Town			Pilani
C	Date Of Collection			4-9-2023
D	Lab. Sample No.			C-26
Sr. No	Parameters	Desirable limits	Permissible limits	Value
1	pH	6.5—8.5	6.5—8.5	7.46
2	Turbidity[NTU]	1	5	Nil
3	Temperature[C]	-----	-----	25
4	Colour[Units]	5 Hazen Unit	15 Hazen Unit	None
5	Odour	Unobjectionable	Unobjectionable	Unobj.
6	Total Alkalinity[asCaCO ₃]	200	600	50
7	Total Hardness[asCaCO ₃]	200	600	50
8	Calcium [asCa]	75	200	12
9	Magnesium [as Mg]	30	100	4.8
10	Chloride[asCl ⁻¹]	250	1000	20
11	Nitrate[as NO ₃ ⁻¹]	45	45	5
12	Fluoride [as F ⁻¹]	1.0	1.5	0.2
13	TDS	500	2000	104

Note: All Results Except pH in mg/L.

(S K Sharma)

Junior Chemist

PHED Laboratory Jhunjhunu

Manager

Birla Shishu Vihar

Pilani - 333031 (Rajasthan)

CBSE Affn. No. : 1730263

PRINCIPAL
BIRLA SHISHU VIHAR
PILANI (RAJ)

PROFORMA FOR SANITARY CONDITION CERTIFICATE

No. 2487

Dated: 9/2/2024

It is certified that an inspection team headed by SURESH KUMAR (S.I.) (Name of Officers with designation) from. MUNICIPAL BOARD VIDYA VIHAR PILANI.

(Name of Department/ Office) inspected the BIRLA SHISHU VIHAR, VIDYA VIHAR PILANI (Name & Address of the school) on 08.02.2024. (date of inspection)

and found that the BIRLA SHISHU VIHAR, VIDYA VIHAR PILANI (Name of school) has safe facilities for the students and members of staff of the institution and is

maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 1 YEARS.

Signature with Seal:

Name PARMOD KUMAR JANGIR
अभिजापी अ. कारी
नगर पालिका विद्या विहार

Designation EXECUTIVE OFFICER पिलानी

Name & Address of the Office / Department
MUNICIPAL BOARD VIDYA VIHAR PILANI

To
PRINCIPAL
BIRLA SHISHU VIHAR,
VIDYA VIHAR
PILANI

Name & Address of the Institution \

PRINCIPAL
BIRLA SHISHU VIHAR
PILANI (RAJ)

Manager
Birla-Shishu Vihar

Pilani - 333031 (Rajasthan)
CBSE Affn. No. : 1730263

* The filled-up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be unloaded along with the original vernacular certificate as a single pdf